

Middle Township Board of Education
 216 South Main Street
 Middle Township, New Jersey 08210

Sent via e-mail: Leadtesting@doe.state.nj.us

To whom it may concern:

On Tuesday April 19, 2022, Middle Township Board of Education conducted lead in drinking water sampling. The lead in drinking water sampling was conducted in accordance with the New Jersey Schools Lead in Drinking Water Regulations; N.J.A.C. 6A:26-1.2;12.4 and the USEPA “3 T’s for Reducing Lead in Drinking Water in Schools”. A total of three hundred and sixty-six (366) drinking water samples were taken from all drinking water outlets to which a student or staff member has or may have access to in the above listed Middle Township Board of Education.

Of the 366 samples taken, all but nineteen (19) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]). In compliance with N.J.A.C. 6A:26-1.2;12.4 twenty-four-hour notification requirements to the Department of Education the table below identifies the water outlets that tested above the 15 ppb for lead, the actual lead level, and what temporary immediate remedial action Middle Township Board of Education has taken to reduce the levels of lead at these locations.

Sample Location	Initial Results in µg/l (ppb)	Flush Results in µg/l (ppb)	Remedial Action
Administration Building Point-of-Entry ID # MTAB-POE	136.9	11.82	Posted as “Do Not Drink-Safe for Handwashing Only”
Elementary School#1 Room CR9 ID#MTEO-WF-09	16.43	16.82	Disconnected outlet and bottled water provided
Elementary School#1 Across from MP Room ID#MTEO-WF-20	61.08	15.75	Disconnected outlet and bottled water provided
Elementary School #1 Room CR35 ID#MTEO-WF-33	80.67	3.531	Disconnected outlet and bottled water provided
Elementary #2 Room CR B3 ID#MTES-WF-16	15.18	0.5923	Disconnected outlet and bottled water provided
Middle School Cafeteria ID# MTMS-WF-05	30.58	13.32	Disconnected outlet and bottled water provided
Middle School Room CR A-5	19.75	3.944	Posted as “Do Not Drink-Safe for Handwashing Only”

Sample Location	Initial Results in $\mu\text{g/l}$ (ppb)	Flush Results in $\mu\text{g/l}$ (ppb)	Remedial Action
ID# MTMS-S-10			
Middle School Across from Media Center ID# MTMS-WF-22	2048	160.7	Disconnected outlet and bottled water provided
Middle School Across from Media Center ID# MTMS-WF-23	75.58	6.013	Disconnected outlet and bottled water provided
Middle School Across from Media Center ID# MTMS-WF-24	21.74	19.71	Disconnected outlet and bottled water provided
Middle School Across from Media Center ID# MTMS-WF-25	29.74	29.19	Disconnected outlet and bottled water provided
Middle School Across Room D-4 ID# MTMS-WF-27	20.67	2.998	Disconnected outlet and bottled water provided
Middle School Gym 1 ID# MTMS-WF-30	44.17	8.834	Disconnected outlet and bottled water provided
Transportation Complex Point-of-Entry ID#MTT-POE	85.62	5.622	Posted as "Do Not Drink-Safe for Handwashing Only"

Commented [PIR1]: Is this ID# for room CR A-5? If so, Are you able to edit so it fits?

Superintendent Name (Print): Dr. David Salvo
 Signature: [Handwritten Signature] Date: 5/23/22